


## SUMMARY OF RESULTS OF TESTING CERTIFICATE 0590 / 13.01.2006

<b>NUMBER</b>	<b>0590</b>	<b>DATE</b>	<b>13 / 01 / 2006</b>
---------------	-------------	-------------	-----------------------

<b>Client' s data:</b>	<b>EXALCO S.A. ALUMINIUM INDUSTRY</b> 8th km. NATIONAL ROAD LARISA-THESSALONIKI GR 411 10 LARISA GREECE
<b>Product description:</b>	<b>DOUBLE SASH DOOR</b> <b>TILT &amp; TURN</b>
<b>Material:</b>	<b>ALUMINIUM</b>
<b>System :</b>	<b>ALBIO 101</b>



2200 x 1400 mm

<b>Air Permeability</b> <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	<b>Class 4</b>
<b>Watertightness</b> <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	<b>Class 8A</b>
<b>Resistance to Wind Load</b> <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	<b>Class C4</b>

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



**SINOPI PAPAPOPOULOU**  
TECHNICAL MANAGER



**IOANNIS GKERTSOS**  
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL