


SUMMARY OF RESULTS OF TESTING CERTIFICATE 0557 / 26.10.2005

NUMBER	0557	DATE	26 / 10 / 2005
---------------	------	-------------	----------------

Client' s data:	EXALCO S.A. ALUMINIUM INDUSTRY 8th km. NATIONAL ROAD LARISA-THESSALONIKI GR 411 10 LARISA GREECE
Product description:	DOUBLE SASH DOOR TILT & TURN
Material:	ALUMINIUM
System :	ALBIO 109



2200 x 1405 mm

Air Permeability <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	Class 4
Watertightness <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	Class 9 A
Resistance to Wind Load <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	Class C5

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



SINOPI PAPAPOULOU
TECHNICAL MANAGER



IOANNIS GKERTSOS
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL